

## **FIRE DOORS**

BCA 1990: Spec C3.4  
BCA 1996: CP8 (Spec C3.4)  
Reference: AS 1905.1  
AS 18517

### **PURPOSE:**

A fire door is installed across an opening in a fire wall to maintain the fire resistance rating of that fire wall.

For further information contact TCM Solutions or <http://www.buildingcommission.com.au>