

## **FIRE RESISTING SHAFTS**

BCA 1990: Section C  
BCA 1996: CP6 (Section C)

### **PURPOSE:**

Shafts provided in buildings for provision of lifts, stairs, ventilation or services, passing from one storey or compartment to another, must have a fire resistance level, to protect those services and the compartments through which they pass.

For further information contact TCM Solutions or <http://www.buildingcommission.com.au>