

## **SMOKE ALARMS**

BCA 1990: E1.7  
Spec E1.7  
Vic- H101.9  
Vic- H103  
BCA 1996: EP2. 1, EP2.2 (Part E2, Spec E2.2a)  
Reference: AS 3786  
AS 1851.8

### **PURPOSE:**

Smoke alarms are installed either singly or in an interconnected circuit. to detect and provide an early warning of the presence of fire.

This early warning is designed to provide as much time as possible to alert occupants of this threat.

For further information contact TCM Solutions or <http://www.buildingcommission.com.au>