

## **SMOKE DOORS**

BCA 1990: C2.5  
Spec C3.4  
BCA 1996: CP3 (C2.5,  
Spec C3.4)  
Reference: AS 1851.7  
AS 1851.8

### **PURPOSE:**

Smoke doors are constructed in smoke walls to restrict the passage of smoke between smoke compartments or walls, or from within a smoke lobby.

For further information contact TCM Solutions or <http://www.buildingcommission.com.au>